

SPILL PREVENTION CONTROL-PERIODIC INSPECTIONS

Well Name and Number _____
 Well Permit Number _____
 Location: County _____ Section/Lot _____ Township _____
 Date of Verification-Calendar Year _____

All oil storage tanks, wellheads, flowlines, brine tanks, drip tanks, separators, piping, controls, valves, dikes, and diversion ditches are to be visually inspected weekly. Proper operation and or satisfactory condition of overall facility is to be verified on a quarterly basis by appropriate supervisor.

<u>Area of Inspection</u>	<u>1st Qtr.</u>	<u>2nd Qtr.</u>	<u>3rd Qtr.</u>	<u>4th Qtr.</u>
Oil Storage Tanks	_____	_____	_____	_____
Wellhead	_____	_____	_____	_____
Flowlines and Piping	_____	_____	_____	_____
Drip Tank	_____	_____	_____	_____
Separator	_____	_____	_____	_____
Controls and Valves	_____	_____	_____	_____
Dikes and Ditches	_____	_____	_____	_____
Overflow Facilities	_____	_____	_____	_____
Supervisor Initial	_____	_____	_____	_____
Oil Storage Tanks Shell Thickness	_____	_____	_____	_____

Note: The date and Nature of any repairs are to be recorded below

Tanks integrity testing per industry standards. A list of organizations which may be helpful are included on page 47058 of the Federal Register Part II 40 CFR Part 112 Preamble. The Appalachian Industrial Standard for shell thickness is 0.167"-0.187" For tank tops and bottoms is 0.200"-0.225".